

# 产品认证证书

## II型自愿认证

证书编号: CQC2014010301734564

发证日期: 2021年04月23日

有效期至: 2031年04月23日

**委托人名称** 苏州工业园区苏容电气有限公司  
**及注册地址** 苏州工业园区创投工业坊6区52号厂房西侧

**制造商名称** 苏州工业园区苏容电气有限公司  
**及注册地址** 苏州工业园区创投工业坊6区52号厂房西侧

**生产企业名称** 苏州工业园区苏容电气有限公司  
**及生产地址** 苏州工业园区娄葑北区创投工业坊52号厂房西侧

**产品名称和系列、规格、型号** 低压智能谐波抑制电力电容补偿装置(低压成套无功功率补偿装置)  
SRZHL In=46.4A~2.3A,Icc=6kA;Ue=380V,Ui=660V;40kvar~2kvar,三相补偿,50Hz,IP30,户内型;控制投切电容器的元件类型:复合开关(单片机CPU控制+磁保持继电器);有抑制谐波功能

**产品标准和技术要求** GB/T 15576-2008

**认证模式** 型式试验+获证后监督

上述产品符合 CQC12-000001-2020 认证规则的要求,特发此证。

证书有效期内本证书的有效性依据发证机构的定期监督获得保持。

可通过扫描下方二维码或登录国家认监委网站(www.cnca.gov.cn)查验证书信息



授权签字人: 主任:

徐军 陆楠

中国质量认证中心



# PRODUCT CERTIFICATION

## TYPE II CQC CERTIFICATION

CERTIFICATE NO.: CQC2014010301734564

Valid from: Apr.23,2021

Valid until: Apr.23,2031

|  |  |
|--|--|
| <b>NAME AND REGISTERED ADDRESS OF THE APPLICANT</b>              | Suzhou Industry Park Surong Electric Co.,ltd<br>West side of No.52 workshop, zone 6, Venture Capital Industrial Park, Suzhou Industrial Park                                       |
| <b>NAME AND REGISTERED ADDRESS OF THE MANUFACTURER</b>           | Suzhou Industry Park Surong Electric Co.,ltd<br>West side of No.52 workshop, zone 6, Venture Capital Industrial Park, Suzhou Industrial Park                                       |
| <b>NAME AND LOCATION OF THE FACTORY</b>                          | Suzhou Industry Park Surong Electric Co.,ltd<br>West side of No.52 factory building of Venture Capital Industrial Square, Loufeng North District, Suzhou Industrial Park           |
| <b>PRODUCT NAME, MODEL AND SPECIFICATION</b>                     | Low-voltage reactive power compensation assemblies<br>SRZHL In=46.4A ~ 2.3A,Icc=6kA;Ue=380V,Ui=660V;40kvar ~ 2kvar,三相补偿;50Hz;IP30,户内型;控制投切电容器的元件类型:复合开关(单片机 CPU 控制+磁保持继电器);有抑制谐波功能 |
| <b>THE STANDARDS AND TECHNICAL REQUIREMENTS FOR THE PRODUCTS</b> | GB/T 15576-2008  |
| <b>TYPE OF CERTIFICATION SCHEMES</b>                             | Type testing+Follow up factory inspection  |

This is to certify that the above mentioned product(s) complies with the requirements of certification rules of CQC12-000001-2020.

The validity of the certificate is subject to positive result of the regular follow up inspection by issuing certification body until the expiry date.

The certificate information is available through the QR code below or CNCA's website: [www.cnca.gov.cn](http://www.cnca.gov.cn)



SIGNED BY:

徐军

PRESIDENT:

陆楠

CHINA QUALITY CERTIFICATION CENTRE

